



DELHI JAL BOARD  
( GOVT. OF N.C.T. DELHI )  
QUALITY CONTROL LABORATORY,  
WATER TREATMENT PLANT NANGLOI, DELHI-110041



Water Sample Analysis report of Samples collected from "Vishwa Bharati Public School", Sector- 06, Dwarka, New Delhi – 110075 Vide Challan No. 165 Dt - 22.09.2025.

S1: DJB Supply at above site

THE TEST REPORT IS  
FOR THIS PARTICULAR  
WATER SAMPLE ONLY.

S2: Drinking Point (RO) at above site.

S. No.	Particulars	Units	Limit		S1	S2
			Acceptable	Permissible		
<b>PHYSICAL EXAMINATION</b>						
1.	Date of collection	-----	--	--	08.10.25	08.10.25
2.	Date of Analysis	-----	--	--	10.10.25	10.10.25
3.	Colour	CU	5.0	15	Clear	Clear
4.	Odour	-----	No. Objectionable		No Obj.	No Obj.
5.	Turbidity	N.T.U.	1.0	5.0	2.6	1.8
6.	PH value	-----	6.5	8.5	7.86	7.68
7.	Electrical Conductivity	µmho/cm	--	--	395.1	169.4
8.	Total dissolved solids	mg/l	500	2000	256.8	110.1
<b>CHEMICAL EXAMINATION</b>						
9.	Phenolphthalein Alkalinity	mg/l	--	--	NIL	Nil
10.	Total Alkalinity	mg/l	200	600	102	50
11.	Total Hardness	mg/l	200	600	144	68
12.	Calcium Hardness	mg/l	--	--	90	46
13.	Magnesium Hardness	mg/l	--	--	54	22
14.	Calcium as Ca	mg/l	75	200	36.0	18.4
15.	Magnesium as Mg	mg/l	30	100	12.96	5.28
16.	Ammonia as N	mg/l	0.5	N.R.	NIL	NIL
17.	Nitrite as N	mg/l	---	--	NIL	NIL
18.	Nitrate as No <sub>3</sub>	mg/l	45	N.R.	3.0	1.6
19.	Sulphate	mg/l	200	400	34	10
20.	Chloride	mg/l	250	1000	54	16
21.	Fluoride	mg/l	1	1.5	0.30	0.10
22.	Dissolved Iron	mg/l	1	N.R.	0.12	ND
23.	Cyanide	mg/l	0.05	N.R.	ND	ND
24.	Residual Chlorine	mg/l	0.20(min)	1.0	0.60	NIL
<b>BACTERIOLOGICAL EXAMINATION</b>						
25.	Coli-form per 100 ml at 37°C	MPN	0	0	0	0

REMARKS: As per tested parameters, Samples S1 & S2 can be used for drinking purpose.

ACWA

Hemlal  
CHEMIST

F BACT.

Asstt. Chief Water Analyst  
DELHI JAL BOARD  
Govt. of N.C.T. Delhi  
Quality Control Laboratory  
Water Works Nangloi, Delhi-41



MUNICIPAL CORPORATION OF DELHI  
OFFICE OF DEPUTY HEALTH OFFICER  
NAJAFGARH ZONE

मानव का प्रयोग करे  
दो गज़ की दूरी बनायें रखे  
हाथ साबुन-पानी में बन्दूक से धोयें  
Corona Virus

No: DHO/NGZ/MCD/2026/D- 1862

Dated- 13/01/2026

SCHOOL HEALTH CERTIFICATE

1. Name of the School: - VISHWA BHARATI PUBLIC SCHOOL
2. SCHOOL ADDRESS:- SEC-6, DWARKA, NEW DELHI-110075
3. NO. OF SHIFT ONE TIMING Morning. 08:00 AM TO 02:00 PM
4. NO. OF STUDENTS: BOYS- 1122 GIRLS – 896 TOTAL = 2018
5. NO. OF STAFFS: MALE - 14 FEMALE – 69 TOTAL = 83

Details of Accommodations present in School

1. Floor Space in the Classroom Sufficient/insufficient **SUFFICIENT**
2. The Classrooms are Well Lighted/ill lighted **WELL LIGHTED**
3. The Classrooms are Well Ventilated/ill ventilated **WELL VENTILATED**
4. The Classrooms are kept / Not kept Neat & Clean: **NEAT AND CLEAN**
5. The Building requires/does not required Whitewash etc. **NOT REQUIRED**
6. The Drinking Water is Wholesome/Not wholesome **WHOLESOOME**
7. The Latrine arrangement is Sanitary/Insanitary **SANITARY FROM HEALTH POINT OF VIEW.**

No. of toilets seats for student

1. One latrine-cum-urinal is required for 25 female student, so total is **SUFFICIENT**
2. One latrine for 40 male student is required so total is **SUFFICIENT**
3. Separate Toilet arrangement for staff present: Yes/No **YES SEPARATE EXISTS FOR STAFF.**
4. The Overall facilities: Good/ Adequate/Inadequate **GOOD FROM HEALTH POINT OF VIEW.**

*If building Department or any other govt. agency takes actions against u/a construction or any dispute, then the Health Certificate will be stand cancelled /revoked without any further intimation in this regard*

Deputy Health Officer  
Deputy Health Officer  
Najafgarh Zone  
Municipal Corporation Of Delhi  
Health Deptt., Najafgarh Zone

*(Remarks: This Certificate is valid for one year from the date of issue and this has no bearing on any unauthorized construction)*

**Note:- (This certificate Valid for School run in B+G+04 upper floors only as per Fire NOC)**